


TYPE "E" INLET
NOT TO SCALE

NOTE:

1. IF PRECAST INLETS ARE NOT USED, INSTALL #4 REINFORCING BARS AT 6" O.C.E.W. IN WALLS.
2. WHERE SIZE OF PIPES PASSING THROUGH INLET EXCEEDS 30", INCREASE INSIDE WIDTH TO DIAMETER OF PIPE PLUS 1'-0" (O.D. + 1'-0")
3. WHERE INLETS ARE LOCATED ON BOX CULVERTS OR OTHER FLAT TOP STRUCTURES, MOUNT THEM PER MANWAY DETAIL WITH APPROXIMATELY SIZED SQUARE OPENING.

MK.	DESCRIPTION	DATE	DWN.	CHK.
				
City of Galveston, Texas				
Department of Public Works				
Storm Sewer Details II				
SHEET NO.:	SCALE:	SHEET		
DATE: MAY, 2012	N.T.S.			
DWN BY:	ONE INCH			
CHKD BY:	IF ABOVE MARK DOES NOT MEASURE ONE INCH, THEN THIS DWG. NOT TO SCALE	OF		